



<p>Routes: Pedestrian and Vehicular</p>							
<p>Routes: Pedestrian and Vehicular General</p>	<p>Generally access routes are considered to be very good throughout the Park. Most routes are considered wide enough to facilitate wheelchair users passing each other.</p> <p>The routes which are shared with council vehicles are also considered generous enough for a wheelchair/buggy to pass by a vehicle safely.</p> <p>The pedestrian route leading from the entrance used by emergency vehicles is possibly the narrowest in the Park measuring 1000mm wide approx.</p>	<p>It is recommended that the width of the pedestrian route adjacent to the Tower is increased in accordance with the provisions in ADM.</p>	<p>ADM 2004 (1.13)</p>	<p>BS 8300: 2001 (5.0)</p>		<p>B</p>	<p>2</p>